

Date 30/04/2026

Serial Number

005852SKGL223HP



BIM Electrical Group Ltd

Minor Works Electrical Certificate For Up To Three Circuits

REQUIREMENTS FOR ELECTRICAL INSTALLATIONS BS 7671 IET WIRING REGULATIONS

To be used only for minor electrical work which does not include the provision of a new circuit

DESCRIPTION

Client

Sau Kuen Goretti Law

Location/Address of Minor Works

223 Homefield Park
SM1 2EA

Description of Minor Works

Alteration to kitchen socket circuit and cooker circuit

Details of departures, if any, from BS 7671 as amended

N/A

INSTALLATION DETAILS

System earthing arrangement: TN-C-S ☒ TN-S ☐ TT ☐

Protective Measures Against Electric Shock

ADS

Risk
assessment
attached?

N/A

Protective Device For Modified Circuit

Circuit 1	Type	BS 61009	Type B	Rating A	32
Circuit 2	Type	BS 61009	Type B	Rating A	32
Circuit 3	Type	N/A	N/A	Rating A	N/A

Comments on existing installation, including adequacy of earthing and bonding arrangements (see 132.16)

N/A

ESSENTIAL TESTS

	Circuit Description	Continuity Ω (fill 1 only)		Insulation resistance M Ω			Polarity	Zs	RCD (if applicable)		RCD Test Button Function
		R1 + R2	R2	Line / neutral	Line / earth	Neutral / earth	$\checkmark$	Ω	1x I Δ n	5x I Δ n	$\checkmark$
1	Cooker	0.19	N/A	999	999	999	$\checkmark$	0.30	N/A	14.6	$\checkmark$
2	Sockets	0.25	N/A	999	999	999	$\checkmark$	0.36	N/A	17.2	$\checkmark$
3	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

DECLARATION

I / We CERTIFY that the works do not impair the safety of the existing installation, that the said works have been designed, constructed, inspected and tested in accordance with BS 7671 (IET Wiring Regulations), as amended to 2018 and that the said works, to the best of my / our knowledge and belief, at the time of my / our inspection complied with BS 7671 except as detailed in Part 1 above.

Name	Engineers Signature	Position	Date
ROSS WATSON		Electrical Inspector	30/04/2026
Reviewed By	QS Signature	Position	Date
TONY FERRAND		Qualified Supervisor	30/04/2026

For and on behalf of

BIM Electrical Group Ltd
Cedar Lodge
Lakeview
Essex

Telephone

Email info@bimsafetygroup.com

Web www.bimsafetygroup.com

Scheme Number (if applicable)



THIS CERTIFICATE IS A VALUABLE DOCUMENT AND SHOULD BE RETAINED FOR FUTURE REFERENCE

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE NOTES

The Minor Works Certificate is intended to be used for additions and alterations to an installation that do not extend to the provision of a new circuit. Examples include the addition of socket-outlets or lighting points to an existing circuit, the relocation of a light switch etc. This certificate may also be used for the replacement of equipment such as accessories or luminaires, but not for the replacement of distribution boards or similar items. Appropriate inspection and testing, however, should always be carried out irrespective of the extent of the work undertaken.

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE GUIDANCE FOR RECIPIENTS (to be attached to the certificate)

This Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with British Standard 7671 (the IET Wiring Regulations). If you were the person ordering the work, but not the owner of the installation, you should pass this certificate, or a copy of it, to the owner.

A separate Certificate should have been received for each existing circuit on which minor works have been carried out. This Certificate is not appropriate if you requested the contractor to undertake more extensive installation work, for which you should have received an Electrical Installation Certificate. The certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this certificate will demonstrate to the new owner that the minor electrical installation work carried out complied with the requirements of British Standard 7671 at the time the certificate was issued.